

Houston Water Southwest Area Chromium-6 Test Results (ppb)

2022 - Present

Location	Feb 2022	May 2022	Aug 2022	Nov 2022	Mar 2023		May 2023	Aug 2023	Nov 2023	Feb 2024	May 2024	Aug 2024	Nov 2024	Feb 2025	May 2025		Sep ^{vi} 2025	Nov 2025	Feb 2026
	0.28	0.22	1.3	0.77	NDiv	Water Plants										0.26	0.17	0.13	
Bellaire Braes	1.2	0.2	2	1.9	NDiv	0.83	1.3	0.98	0.31	0.29	1.3	0.57	0.96	0.36	0.24	0.53	1.1		
Bellaire Braes Well 1	4.6	5.7	5.1	5.6	4.8	0.65	NCv						1.4	1.8	1.2	2.7	4.5	5	
Brookfield District	4	NCv	3.8	4.5	3.2	4.5	4.5	5.6	NCv	6	4.8	5.4	5	5.3	6.2	6.0	6.2		
90-2	5	5.6	5	4.6	4.2	4.1	3.3	5.2	3.0	4.5	4.0	4.0	3.4	3.8	6.3	4.6	5.7		
District 111-2	3.9	3.3	3.9	4.1	1.9	4.7	4.5	6.3	0.15	6.5	5.8	5.1	4.9	5.9	2.2	2.3	2.8		
District 123	3					1.9	2	2.1	4.1	NCv			2	1.9					
District 184 Park	2.6	NCv																	
Parkglen-1	4.7	0.04	1.7	3.7	2.7	5.4	4.5	4.5	5.6	1.1	5.4	5.3	5.3	5.5	3.6	4.9	4.3		
West		NC ^v	4.6	NC ^v			3.8	3.5	0.47	4.6	4.7	0.48	3.5	3.7	4.8	3.9	4.6		
Distribution Sample Points (DSP)																			
Collected to Monitor Levels Observed in Water Lines Near Customer Homes																			
DSP District 111- 2i	5.2	5.5	5	4.3	1.6	4.5	4.9	6.5	0.29	0.62	1.9	5.4	1	0.35	0.23	4.6	0.16		
DSP 100 iii	2.8	3.2	1.1	3.8	4.2	4.9	4.4	0.91	0.29	1.2	1.5	1.4	1.6	2.2	5.1	5.0	2.7		
DSP Parkglen MUDii	1.6	0.48	1.4	0.95	1.2	1.5	0.68	3.8	0.84	0.54	4.6	0.6	0.92	1.1	0.24	1.8	0.14		

i.D-111-2 is water from Bellaire Braes, District 111-2, and Brookfield Facilities.

ii.Parkglen MUD is water from District 184, District 90-2, District 123, and Parkglen West Groundwater Facilities.

iii.100 represents Parkglen-1 Groundwater Facility.

iv.ND - Not Detected.

v.NC - Not Collected due to plant out of service.

vi. Hex Cr samples cancelled due to subcontract lab exceeding hold time; resampled in September.